

school ID = 1309284



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7-  
सुभाष  
सुभाष

11


No. F6/DFS/MS/2023/School/ NW2 | 16

Dated: 06/01/2023

FIRE SAFETY CERTIFICATE

Certified that the Rao Mahar Chand Saraswati Vidya Mandir located at Guru Nanak Nagar, Delhi-110042 comprised of ground & first floor owned/ occupied by the Rao Mahar Chand Saraswati Vidya Mandir was issued fire safety certificate vide this office letter no. F6/DFS/MS/2019/WZ/School/2354 dated 20.12.2019. The premises was re-inspected by the officer concerned of this department on 28.12.2022 in presence of Mr. Bhuwan Chand and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from ...06/01/2023 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ...06/01/2023... at New Delhi

  
(Dharmpal Bhardwaj)  
Dy. Chief Fire Officer  
Ph:-011-23414250


Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Arya Vidya Mandir located at Pratap Nagar, Delhi-110007.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

Receive  
SyoH

  
Principal  
Guru Nanak Nagar  
Bhalaswa Dairy  
Near Gurudwara